




# **Modular surge protective devices (SPDs)**

Cat. Nos: 4 122 20/21/23/24/25/26/27/30/32/33/ 40/41/42/43/44/45/46/47/50/51/52/53/54/55/56/57 70/71/72/73/74/75/76/77







CC	ONTENTS	Page
1.	General characteristics	1
2.	Dimensions	4
3.	Technical characteristics	4
4.	Conformity	10
5.	Installation	10
6.	Accessories	12

# 1. GENERAL CHARACTERISTICS

### ■ 1.1 Brief description

Surge protective devices for installations supplied with 230/400 V~ (50-60 Hz).

Equipped with plug-in modules with status indicator:

- Green: SPD operational
- Orange: plug-in module needs to be replaced

Equipped with an auxiliary unit for the remote monitoring of the SPD status (depending on the version).

SPDs T1+T2/8 kA and 12,5 kA (class I + II): recommended for general protection of main distribution boards.

SPDs T1+T2/12.5 kA (class I + II): recommended for small installations with lightning conductor/LPS protection (level III/IV LPS) and power installations without lightning conductor/LPS.

SPDs T1+T2/25 and 35 kA (class I + II): recommended for power installations with lightning conductors or LPS.

SPDs T2 (class II): recommended for the protection of secondary distribution boards.

LPS: lightning protection system according to standards EN/IEC 62305

### ■ 1.2 Protection modes

### SPDs 1P+N/3P+N

TT, TNS systems


	N N N N N N N N N N N N N N N N N N N
4 122 24	4 122 26
4 122 25	4 122 27
4 122 44	4 122 46
4 122 45	4 122 47
4 122 54	4 122 56
4 122 55	4 122 57
4 122 74	4 122 76
4 122 75	4 122 77

Surge protective devices with L-N and N-PE protection modes (common and differential protection modes), the neutral (N) being protected by encapsulated spark gaps with higher power capacities than the phase protection. Also called mode "1+1" or "connection type 2" (CT2) according to standards HD/IEC 60364 clause 534.

Technical data sheet: F02060EN/05 Updated: 28/02/2019 Created: 07/01/2015

#### SPDs 1P/2P/3P/4P

TT, TN (TNC, TNS), IT systems





IT 230/400 V~  $\rightarrow$  Uc 440 V~

Surge protective devices with L-PE and N-PE protection modes (common modes). Also called mode "X+0" or "connection type 1" (CT1) according to standards HD/IEC 60364 clause 534.

### Two-phase mains supplies

Technical data sheet: F02060EN/05

Use SPDs 1P or 2P.

Two-phase mains supplies (L1-L2)						
Voltage ≤ 230 V~	Voltage > 230 V~					
4 122 20/21	4 122 30					
4 122 40/41						
4 122 50/51						
4 122 70/71						

### ■ 1.3 Applications

#### 1.3.1 Installation standards

#### 1.3.1.1 NF C 15-100

According to this standard, SPDs are compulsory at the source of any new (or refurbishment) installation that is:

- equipped with an LPS (lightning protection system) or lightning conductor (also see section 1.3.3)
- supplied with overhead power lines when located in a geographical area classified AQ2 (Nk > 25)

In the latter case, a lack of SPDs can however be justified by a risk analysis according to the UTE C 15-443 guide, standard IEC 60364-4-443 or any other recognised equivalent method.

An SPD may also be required in geographical areas classified AQ2 for certain installations:

- with home-based medical services
- equipped with security systems for people and property (fire alarm, technical or social alarms, etc.).

#### Note

SPDs are usually recommended anywhere where the safety of people may depend directly or indirectly on the continuity of service of this equipment.

The use of SPDs is also strongly recommended in mountainous areas, near large bodies of water or dominant structures (tall buildings, trees, etc), for installations at the end of a line or located less than 50 m from buildings equipped with a lightning conductor.

Nk = keraunic level (number of days a year when lightning strikes occur in a given area)

Ng = Nk/10 where Ng: number of strikes a year per  $km^2$ .

Installations with a lightning conductor or a LPS (or equipped with something that can act as a lightning conductor, such as a metal structure higher than the surrounding buildings, aerials, etc):

- Type 1 or Type 1+ Type 2 SPD (limp ≥ 12.5 kA) compulsory at the installation source (main distribution board in secondary buildings)
- Installations more than 10 m high (apartment buildings, office buildings, hotels, etc): Type 2 SPD recommended for protecting private areas and floor distributors (communal areas) in addition to a Type 1 or Type 1 + Type 2 SPD
- Installations with numerous private areas (apartment buildings, office buildings, etc): Type 2 SPD where In  $\geq 5$  kA compulsory at the source of each private area if the Type 1 or Type 1 + Type 2 SPD cannot be installed at the installation source.

### 1.3.1.2 HD 60364, IEC 60364

According to articles 443 and 534 of standards HD/IEC 60364 and guides TS/IEC 61643-12, the use of SPDs in new or renovated buildings is compulsory at the supply end of the installation in the following cases:

- Buildings with lightning conductors or a LPS (T1 or T1+T2 SPD, limp  $\geq$  12.5 kA)
- Buildings with totally or partially overhead power supplies in AQ2 geographical areas (article 443.3.2.1 AQ2: Nk > 25) and based on a risk assessment taking into account the type of power supply to the building (article 443.3.2.2)

According to article 443.3.2.2, SPDs (Type 2) are also required in the following cases:

- Commercial/industrial buildings, public services, religious buildings, schools, large residential complexes, etc.
- Hospitals and buildings containing medical equipment and/or security systems for people and property (fire alarms, technical alarms, etc)

#### 1.3.2 Legrand recommandations

To ensure correct protection, an SPD is recommended:

- at the origin of each installation (compulsory depending on the type and location of the installation to be protected)
- at secondary distribution board feeding sensitive equipment
- on all outdoor electrical circuit outgoing lines (power supply for secondary buildings, outdoor lighting or outdoor distribution boards, etc).

It is obligatory to install an SPD when the safety of people may depend on the continuity of service of equipment (even if this is not required by national standards). Although not compulsory according to the installation standards, an SPD should always be installed for communication networks to protect the communication equipment when there is an SPD on the low voltage power network.

To define the type of SPD needed according to the installation level of risk, use the selection chart (see catalogue) or our XLPRO<sup>3</sup> and XLPRO<sup>3</sup> Calcul software.

#### 1.3.3 EN 62305 (IEC 62305)

An external lightning protection system (LPS) protects buildings against direct lightning strikes. It is generally based on the use of lightning conductors (single rods, with ESE, meshed cage, etc.) and/or the metal structure of the building.

If there is an LPS or a lightning risk assessment has been carried out in accordance with standards EN/IEC 62305, SPDs are generally required in the main distribution board (T1 or T1+T2 SPDs) and distribution boards (T2 SPDs).

Determination of SPDs in the main distribution board according to EN/IEC 62305 and TS/IEC 61643-12 (if there is insufficient information available):

Buildings with an external LPS

-				
LPL <sup>(1)</sup> : Lightning protection level			Usage practices	
ı	200 kA	25 kA/pole (IT: 35 kA min.)	Power installations	
II	150 kA	18.5 kA/pole	Rarely used	
III/IV	100 kA	12.5 kA/pole	Small installations	

(1): LPL (Lightning Protection Level)

### Note:

According to standards EN/IEC 62305, T1 and T1+T2 SPDs may also be required if there is a risk of direct impact on power lines (EN/IEC 62305-1 table E.2). However, according to standard EN 62305-4 (appendix C.2.2), this is only the case if a risk of direct impact on the last 50 m of the line really exists and if this risk really has to be taken into account.

### Risk assessment according to EN/IEC 62305

The risk assessment aims to evaluate if protective measures are needed. It defines their type and the level of needs to protect a building against lightning impacts (lightning protection of the building with an external LPS) and to protect equipment against impacts on the power or data lines, and against transient overvoltages due to lightning impacts on the LPS or close to the building.


To evaluate if protective measures are needed, it takes into account the following criteria:


- dimensions and type of construction of the building, type and level of use, type and number of lines entering the building, surrounding environment and local lightning density, number of persons usually present, etc...
- possible origins of the threats (S1: impacts on the building, S2: impacts close to the building, S3: impacts on the lines, S4: impacts close to the lines)
- possible losses or damages (L1: human safety, L2: public services, L3: cultural heritage and L4: economic value)
- and the level of acceptable risks depending on the type of building and its final use.

When the calculated risk is too high (higher than the acceptable level), protective measures must be implemented (LPS, SPDs, earthings, ...) and adapted to the level of needs. This level of needs is expressed in terms of LPL (Lightning Protection Level) with values ranging from I to IV, a LPL of I being the highest level of needs corresponding to a lightning current discharge of 200kA on the SPF and to T1 or T1+T2 SPDs of 100kA (25kA/pole for 4P SPDs) to be installed at the main board. LPL: see table above.

### 2. DIMENSIONS

# ■ 2.1 1P+N/3P+N/1P/2P/3P/4P catalogue numbers without auxiliary for SPD status monitoring






Type of	Dimensions (mm)								
SPD	а	b	с	d	e	f			
1P	17,7	83	88,3	63,3	50,2	69,5			
1P+N / 2P	35,4	83	88,3	63,3	50,2	69,5			
3P	53,1	83	88,3	63,3	50,2	69,5			
3P+N / 4P	70,8	83	88,3	63,3	50,2	69,5			

# ■ 2.2 1P+N/3P+N/3P/4P catalogue numbers with auxiliary for SPD status monitoring






ı	Type of	Dimensions (mm)								
	SPD	a	b	C	d	e	f	g		
	1P+N	35,4	91,9	97,2	76,5	63,3	50,2	69,5		
ĺ	3P	53,1	91,9	97,2	76,5	63,3	50,2	69,5		
	1P+N / 4P	70,8	91,9	97,2	76,5	63,3	50,2	69,5		

### 3. TECHNICAL CHARACTERISTICS


### ■ 3.1 Operating positions

Vertical, horizontal or on its side



Fixed on EN 60715 or DIN 35 rail

### ■ 3.2 Minimum distance from any earthed conductive surface



### ■ 3.3 Enclosure materials

#### Base

Fibreglass reinforced (10%) polycarbonate (PC)

Self-extinguishing: 850°/30 s

Colour: RAL 7035 light grey

### Plug-in module:

Fibreglass reinforced (30%) polybutylene terephthalate (PBT)

Self-extinguishing: 960°/30 s

Colour: RAL 7035 light grey

### ■ 3.4 Metal component materials

Cage terminals: zinc-plated steel

Terminal screws: zinc-plated steel

Base contacts: tinned copper, nickel-plated copper

Springs: stainless steel

Plug-in module contacts: tinned bronze, nickel-plated bronze, brass

Rivet: aluminium

# ■ 3.5 Resistance to shock and vibrations Sinusoidal vibrations

# - In accordance with IEC 60721-3-3

- Frequency range: 1 to 150 Hz
- Duration: 10 cycles
- Displacement: 3.5 mm
- Acceleration: 1 g where  $g = 9.81 \text{ m/s}^2$

# Shock

- In accordance with IEC 60721-3-3
- Acceleration: 15 g where  $g = 9.81 \text{ m/s}^2$

### ■ 3.6 Detailed characteristics

Technical data sheet: F02060EN/05

## SPDs T1+T2 - 1P+N/3P+N

	Cat. Nos.		4 122 54/56	4 122 55/57	4 122 74/76	4 122 75/77		
Number of poles			1P+N	3P+N	1P+N	3P+N		
Type of SPD			T1+T2/8 kA	T1+T2/8 kA	T1+T2/12.5 kA	T1+T2/12.5 kA		
Maiı	ns supply		230 V~ 240 V~	230/400 V~ 240/415 V~	230 V~ 240 V~	230/400 V~ 240/415 V~		
Max	imum supply fluctuation				(400 V~) +10% (415 V~) +6%			
Frec	uency			50/6	60 Hz			
Eart	hing system			TT,	TNS			
Prot	ection modes			L-N/N-I	PE/L-PE			
		L-N		320	) V~			
Max	. continuous operating voltage (Uc)	N-PE		255	5 V~			
		L-PE		320	) V~			
		L-N	8 kA	8 kA	12.5 kA	12.5 kA		
	Impulse discharge current (limp, 10/350)	N-PE	16 kA	25 kA	25 kA	50 kA		
		L-PE	8 kA	8 kA	12.5 kA	12.5 kA		
T1	Total discharge current (L+N)/PE (Itotal, 10/350)		16 kA	25 kA	25 kA	50 kA		
		L-N	1.2 kV	1.2 kV	1.5 kV	1.5 kV		
	Protection level at limp	N-PE	1.5 kV	1.5 kV	1.5 kV	1.5 kV		
		L-PE	1.5 kV	1.5 kV	1.6 kV	1.6 kV		
		L-N	20 kA	20 kA	25 kA	25 kA		
	Nominal current In (8/20)	N-PE	20 kA	20 kA	25 kA	50 kA		
		L-PE	20 kA	20 kA	25 kA	25 kA		
	Imax (8/20)	-N/N-PE/L-PE	50 kA	50 kA	60 kA	60 kA		
T2	Total discharge current (L+N)/PE (Itotal, 8/20)		60 kA	60 kA	60 kA	125 kA		
		L-N	1.7 kV	1.7 kV	1.9 kV	1.9 kV		
	Protection level (Up) at In	N-PE	1.5 kV	1.5 kV	1.5 kV	1.5 kV		
		L-PE	2 kV	2 kV	2.1 kV	2.1 kV		
		L-N	1 kV	1 kV	1 kV	1 kV		
Prot	ection level (Up) at 5 kA	N-PE	1.5 kV	1.5 kV	1.5 kV	1.5 kV		
		L-PE	1.1 kV	1.1 kV	1.1 kV	1.2 kV		
Гет	porary overvoltages (LV supply faults)		L-N: 336 V/5 s (withstand mode) L-PE: 440 V/5 s (withstand mode) L-N: 440 V/2 hrs (failure mode)					
Tem	porary overvoltages (HV supply faults)		1200 V (withstand mode)					
Prot	ective device to be used : circuit breakers, fuses		See 3.7					
Sho	rt-circuit current withstand (Isccr, Isc max)		50 kA					
Follo	ow current (Ifi)		N-PE = 100 A					
Resi	dual current at Uc (I <sub>pF</sub> )		0 A					
	ponse time		L/N: 25 ns; N/PE: 100 ns					
	ninal capacity: solid or flexible wire ninal capacity: flexible wire with ferrule		6/35 mm <sup>2</sup> 6/25 mm <sup>2</sup>					
Aux	liary contact for remote monitoring of SPD status		No	No 250 V~ - 1A -	Yes 1.5 mm² max	Yes		
Polli	ution level				2			
	ation category		Indoor					
	nber of ports							
	hod of mounting				red			
	th (number of modules)		2	4	2	4		
	ection index		IP 20 (only when all terminals are used) / IK 04					
	rating temperature			•	o +70°C			
	age temperature				o +70°C			
اللا	nidity range				- 95 %			

Created: 07/01/2015 **La legrand** 

## SPDs T2 - 1P+N/3P+N

Technical data sheet: F02060EN/05

Number of poles Type of SPD  Mains supply  Maximum supply fluctuation  Frequency		1P+N T2/20 kA 230 V~ 240 V~	3P+N T2/20 kA 230/400 V~	1P+N T2/40 kA	3P+N T2/40 kA		
Mains supply  Maximum supply fluctuation		230 V~	230/400 V~		T2/40 kA		
Maximum supply fluctuation							
			240/415 V~	230 V~ 240 V~	230/400 V~ 240/415 V~		
Frequency			(230 V~; 230/- (240 V~; 240/-				
			50/6	0 Hz			
Earthing system			TT,	ΓNS			
Protection modes			L-N/N-F	PE/L-PE			
	L-N		320	V~			
Max. continuous operating voltage (Uc)	N-PE		255	V~			
	L-PE		320	V~			
	L-N	5 kA	5 kA	20 kA	20 kA		
Nominal current In (8/20)	N-PE	20 kA	20 kA	20 kA	20 kA		
	L-PE	5 kA	5 kA	20 kA	20 kA		
Imax (8/20) L-N/	N-PE/L-PE	20 kA	20 kA	40 kA	40 kA		
Total discharge current (L+N)/PE (Itotal, 8/20)		40 kA	60 kA	60 kA	60 kA		
	L-N	1.2 kV	1.2 kV	1.7 kV	1.7 kV		
Protection level (Up) at In	N-PE	1.4 kV	1.4 kV	1.4 kV	1.4 kV		
· • ·	L-PE	1.4 kV	1.4 kV	2 kV	2 kV		
	L-N	1.2 kV	1.2 kV	1 kV	1 kV		
Protection level (Up) at 5 kA	N-PE	1.4 kV	1.4 kV	1.4 kV	1.4 kV		
	L-PE	1.4 kV	1.4 kV	1.1 kV	1.1 kV		
	L-N	1.4 kV	1.4 kV	1.2 kV	1.2 kV		
Residual voltage at 10 kA	N-PE	1.4 kV	1.4 kV	1.4 kV	1.4 kV		
- h	L-PE	1.4 kV	1.4 kV	1.4 kV	1.4 kV		
	L-N			1.5 kV	1.5 kV		
Residual voltage at 15 kA	N-PE			1.4 kV	1.4 kV		
- h	L-PE			1.6 kV	1.6 kV		
Temporary overvoltages (LV supply faults)		L-N: 336 V/5 s (withstand mode) L-PE: 440 V/5 s (withstand mode) L-N: 440 V/2 hrs (failure mode)					
Temporary overvoltages (HV supply faults)		1200 V (withstand mode)					
Protective device to be used : circuit breakers, fuses		See 3.7					
Short-circuit current withstand (Isccr, Isc max)		25	kA	50	kA		
Follow current (Ifi)			N-PE =	100 A			
Residual current at Uc (I <sub>pp</sub> )		0 A					
Response time		L/N: 25 ns; N/PE: 100 ns					
Terminal capacity: solid or flexible wire Terminal capacity: flexible wire with ferrule		6/35 mm <sup>2</sup> 6/25 mm <sup>2</sup>					
Auxiliary contact for remote monitoring of SPD status		No No					
Pollution level		2					
Location category			Ind	oor			
Number of ports		1					
Method of mounting			Fix	ed			
Width (number of modules)		2 4 2 4					
Protection index		IP 20 (only when all terminals are used) / IK 04					
Operating temperature		-25°C to +70°C					
Storage temperature			-40°C to	) +70°C			
Humidity range			HR:5	- 95 %			

Created: 07/01/2015 **L7 legrand** 

### SPDs T1+T2 - 1P/2P/3P/4P

Technical data sheet: F02060EN/05

	Cat. Nos.	4 122 50/51	4 122 52	4 122 53	4 122 70/71	4 122 72	4 122 73	
Nun	nber of poles	1P/2P	3P	4P	1P/2P	3P	4P	
Туре	of SPD	T1+T2/8 kA	T1+T2/8 kA	T1+T2/8 kA	T1+T2/12.5 kA	T1+T2/12.5 kA	T1+T2/12.5 kA	
Maii	ns supply		230 V~ 240 V~	400 V~ 415 V~	230/400 V~ 240/415 V~	230 V~ 240 V~	400 V~ 415 V~	230/400 V~ 240/415 V~
Max	imum supply fluctuation					V~; 400 V~) +10% 5 V~; 415 V~) +6%		
Fred	uency				50/6	50 Hz		
Eart	hing system		TT, TNS	TNC	TT, TNS	TT, TNS	TNC	TT, TNS
Prot	ection modes				L(N	I)-PE		
Max	. continuous operating voltage (Uc)	L(N)-PE			32	0 V~		
	Impulse discharge current (limp, 10/350)	L(N)-PE		8 kA			12.5 kA	
T1	Total discharge current (L+N)/PE (Itotal, 10/350)		2P: 16 kA	25 kA	32 kA	2P: 25 kA	37.5 kA	50 kA
	Protection level at limp	L(N)-PE	1.2 kV	1.2 kV	1.2 kV	1.5 kV	1.5 kV	1.5 kV
	Nominal current In (8/20)	L(N)-PE		20 kA			25 kA	
	Imax (8/20)	L(N)-PE		50 kA			60 kA	
T2	Total discharge current (L+N)/PE (Itotal, 8/20)	•	2P: 100 kA	125 kA		2P: 120 kA	125	5 kA
	Protection level (Up) at In	L(N)-PE	1.7 kV	1.7 kV	1.7 kV	1.9 kV	1.9 kV	1.9 kV
Prot	ection level (Up) at 5 kA	L(N)-PE	1 kV	1 kV	1 kV	1 kV	1 kV	1 kV
Temporary overvoltages (LV supply faults)			L-PE: 440 V/5 s (withstand mode) L-N(L-PEN): 440 V/2 hrs (failure mode)					
Tem	porary overvoltages (HV supply faults)		1200 V + 255 V (failure mode)					
Prot	ective device to be used : circuit breakers, fuses		See 3.7					
Sho	t-circuit current withstand (Isccr, Isc max)		50 kA					
Resi	dual current at Uc (I <sub>pr</sub> )		lpe < 0.5 mA					
Resp	oonse time		25 ns					
	ninal capacity: solid or flexible wire ninal capacity: flexible wire with ferrule		6/35 mm <sup>2</sup> 6/25 mm <sup>2</sup>					
			No	No	No	No	Yes	No
Aux	liary contact for remote monitoring of SPD status		250 V~ - 1A - 1.5 mm² max					
Poll	ution level					2		
Loca	tion category		Indoor					
Nun	nber of ports		1					
Met	nod of mounting				Fi	xed		
Width (number of modules)		1 (4 122 50) 2 (4 122 51)	3	4	1 (4 122 70) 2 (4 122 71)	3	4	
Prot	ection index		IP 20 (only when all terminals are used) / IK 04					
Оре	rating temperature		-25°C to +70°C					
Stor	age temperature		-40°C to +70°C					
Hun	nidity range				HR:5	- 95 %		

### SPDs T2 - 1P/2P/3P/4P

Technical data sheet: F02060EN/05

Cat. Nos.	4 122 20/21	4 122 23	4 122 40/41	4 122 42	4 122 43		
Number of poles	1P/2P	4P	1P/2P	3P	4P		
Type of SPD		T2/20 kA	T2/20 kA	T2/40 kA	T2/40 kA	T2/40 kA	
Mains supply		230 V~ 240 V~	230/400 V~ 240/415 V~	230 V~ 240 V~	400 V~ 415 V~	230/400 V~ 240/415 V~	
Maximum supply fluctuation				~; 230/400 V~; 400 V~ ~; 240/415 V~; 415 V			
Frequency				50/60 Hz			
Earthing system		TT,	TNS	TT, TNS	TNC	TT, TNS	
Protection modes				L(N)/PE			
Max. continuous operating voltage (Uc)	L(N)-PE			320 V~			
Nominal current In (8/20)	L(N)-PE	5 kA	5 kA	20 kA	20 kA	20 kA	
lmax (8/20)	L(N)-PE	20 kA	20 kA	40 kA	40 kA	40 kA	
Total discharge current (L+N)/PE (Itotal, 8/20)		2P: 40 kA	80 kA	2P: 80 kA	120 kA	125 kA	
Protection level (Up) at In	L(N)-PE	1.2 kV	1.2 kV	1.7 kV	1.7 kV	1.7 kV	
Protection level (Up) at 5 kA	L(N)-PE	1.2 kV	1.2 kV	1 kV	1 kV	1 kV	
Residual voltage at 10 kA	L(N)-PE	1.4 kV	1.4 kV	1.2 kV	1.2 kV	1.2 kV	
Residual voltage at 15 kA	L(N)-PE			1.5 kV	1.5 kV	1.5 kV	
Temporary overvoltages (LV supply faults)	·	L-PE: 440 V/5 s (withstand mode) L-N(L-PEN): 440 V/2 hrs (failure mode)					
Temporary overvoltages (HV supply faults)		1200 V + 255 V (failure mode)					
Protective device to be used : circuit breakers, fuses		See 3.7					
Short-circuit current withstand (Isccr, Isc max)		25 kA 50 kA					
Residual current at Uc (I <sub>PE</sub> )		Ipe < 0.5 mA					
Response time		25 ns					
Terminal capacity: solid or flexible wire Terminal capacity: flexible wire with ferrule		6/35 mm² 6/25 mm²					
		No	No	No	Yes	No	
Auxiliary contact for remote monitoring of SPD status		250 V~ - 1A - 1.5 mm² max					
Pollution level		2					
Location category		indoor					
Number of ports				1			
Method of mounting				Fixed			
Width (number of modules)	1 (4 122 20) 2 (4 122 21)	4	1 (4 122 40) 2 (4 122 41)	3	4		
Protection index	IP 20 (only when all terminals are used) / IK 04						
Operating temperature		-25°C to +70°C					
Storage temperature		-40°C to +70°C					
Humidity range		HR: 5 - 95 %					

### SPDs T2 - 1P/2P/3P/4P (400 V~)

Cat. Nos.		4 122 30	4 122 32	4 122 33		
Number of poles	ber of poles 1P 3P					
Type of SPD		T2/40 kA T2/40 kA T2/40 k				
Mains supply		400 V~ 415 V~	400 V~ 415 V~	230/400 V~ 240/415 V~		
Maximum supply fluctuation			(230/400 V~; 400 V~) +10% (240/415 V~; 415 V~) +6%			
Frequency			50/60 Hz			
Earthing system		TT, TNC, TNS, IT	TNC, IT	TT, TNS, IT		
Protection modes			L(N)/PE			
Max. continuous operating voltage (Uc)			440 V~			
Nominal current In (8/20)			20 kA			
lmax (8/20)			40 kA			
Total discharge current (L+N)/PE (Itotal, 8/20)			120 kA	125 kA		
Protection level (Up) at In	L(N)-PE		2.1 kV			
Protection level (Up) at 5 kA	L(N)-PE		1.3 kV			
Residual voltage at 15 kA	L(N)-PE		1.8 kV			
Temporary overvoltages (LV supply faults)		L-PE: 440 V/5 s (withstand mode) L-N(L-PEN): 440 V/2 hrs (failure mode)				
Temporary overvoltages (HV supply faults)		1200 V + 440 V (failure mode)				
Protective device to be used : circuit breakers, f	uses	See 3.7				
Short-circuit current withstand (Isccr, Isc max)		50 kA				
Short-circuit current withstand (Isccr, IT 400V~	L-PE)	4.5 kA				
Residual current at Uc (I <sub>PE</sub> )		lpe < 0.5 mA				
Response time			25 ns			
Terminal capacity: solid or flexible wire Terminal capacity: flexible wire with ferrule		6/35 mm² 6/25 mm²				
A :11:	.1.1	No	Yes	Yes		
Auxiliary contact for remote monitoring of SPD	status	250 V~ - 1A - 1.5 mm² max				
Pollution level		2				
Location category		Indoor				
Number of ports		1				
Method of mounting		Fixed				
Width (number of modules)		1 3 4				
Protection index		IP 20	(only when all terminals are used)	/ IK 04		
Operating temperature		-25°C to +70°C				
Storage temperature		-40°C to +70°C				
Humidity range		<u> </u>	HR : 5 - 95 %	<u> </u>		

### ■ 3.7 Maximal protective devices used with SPDs

		23					
	0	TT		TT TN		ø:	
		1P/2P 3P/4P	1P+N / 3P+N			(X, Y, Z)	
T1+T2/12,5 kA	<b>─</b> /₩		C63			> 16 mm?	
11+12/12,5 KA			≥ 16 mm <sup>2</sup>				
T1+T2/8 kA	<b>─</b> /₩			≥ 10 mm <sup>2</sup>			
11+12/6 KA			gG ≤ 80 A		2 10 1111111		
T2/40 kA	<b>─</b> /₩				≥ 10 mm <sup>2</sup>		
Uc = 440 V			≥ 10 mm²				
T2/40 kA	<b>─</b> /₩	C40				40 3	
Uc = 320 V —			gG ≤ 63 A		≥ 10 mm <sup>2</sup>		
T2/20 kA	<b>─</b> /₩	C20				≥ 6 mm <sup>2</sup>	
12/20 KA			gG ≤ 40 A		≥omm²		

According to national regulations, the conductor may not be protected or cut. At minima, cut of neutral conductor recommended for purposes of easy maintenance and easy controls of the insulation resistance of the installation. In this case, apply the normal rules of the neutral system to choose protections with neutral protected or cut.

Two-phase mains supplies: 2P circuit breakers only (ratings: see above)

By default, the rating of the circuit-breaker or fuse must be the maximum rating indicated. If a selectivity is sought with upstream protection then it is possible to use a lower caliber but 3 levels max according to the Renard series.

Ex: Max protection is 125 A ---> rating min = 63 A

In this case, it is strongly recommended to use the auxiliary to report the circuit-breaker status and thus prevent undesired operation of the circuit-breaker during overvoltage treatment.

### 4. CONFORMITY

Conforming to standards EN 61643-11:2012 and IEC 61643-11 edition 1: 2011.

These SPDs ensure compliance with the installation obligations and recommendations of standards NF C 15-100 (HD/IEC 60364) part 534, standards IEC/EN 62305 and guide UTE C 15-443 (TS/IEC 61643-12).

Conforming to directives 2014/35/UE.

# 5. INSTALLATION

### ■ 5.1 General principle


Surge protective devices must not be installed in locations where there is a risk of fire or explosion without special provisions. They must be disconnected before checking the insulation resistance of the installation.

### ■ 5.2 Types of SPD and earthing systems

Residual current devices and continuity of service: if the main distribution board protective device located upstream of the SPD includes a residual current device, this must be type S or delayed at the installation source (residual current device immunised against overvoltages up to 5 kA in accordance with standard NF C 15-100 and 3 kA in accordance with standard HD/IEC 60364). Also recommended for secondary distribution boards.

When possible (according to local rules), the SPD and its associated protective device should be installed upstream of the main protective device as shown below (in accordance with standards HD/IEC 60364).

### SPDs and TT earthing system



P1: main protective device of the installation

P2: protective device used with the SPD (see 3.6.2)

SPD: surge protective device with Uc 275 or 320 V recommended


(upstream of P1): SPDs 1P+N/3P+N only (except for Cat. Nos. 0 039 51/53/71/73).

SPDs 1P/2P/3P/4P and Cat. Nos. 039 51/53/71/73 must always be installed downstream of a residual current device (discriminating or delayed, at the origin of the installation).

(downstream of P1): any SPD

Technical data sheet: F02060EN/05

### SPDs and TN (TNC, TNS and TNC-S) earthing systems




P1: main protective device of the installation

P2: protective device used with the SPD (see 3.6.2)

SPD: surge protective device with Uc 275 or 320 V recommended

### SPDs and IT earthing system (230/400 V~)

Cat. Nos 4 122 30/32/33



P1: main protective device of the installation

P2: protective device used with the SPD (see 3.6.2)

SPD: surge protective device with Uc 440 V (Uc < 440 V prohibited)

### Two-phase mains supplies

Use SPDs 1P or 2P.

Associated protective device: see section 3.6.2

### ■ 5.3 Connections


Check that the earth connection to which the exposed conductive parts of the installation are connected complies with standard NF C 15-100 (HD/IEC 60364).

SPD connected to the mains supply and to the protective conductor (PE) using as short a connection as possible,  $X+Y+Z \le 50$  cm.

Compulsory connection of the earth terminal on the surge protective device to the protective conductor (PE) on the distribution board.

Equipotentiality rules: interconnection of the exposed conductive parts of the equipment and the protective conductor (PE) on the distribution board, which is itself connected to the earth terminal of the surge protective device.

Electromagnetic compatibility rules: avoid loops, fix the cables firmly against the exposed metal conductive parts.



1 Protective device used with the SPD (see 3.6.2)

Recommended connection cross-sections and lengths to be stripped:

14 mm	6 - 35 mm²
14 mm	6 - 35 mm² 6 - 25 mm² (with ferrule)

### Tools required and tightening torque


Flat blade screwdriver Ø 4 to 6.5 mm

Crosshead screwdriver Ø 4 to 6.5 mm, Pozidriv PZ2 recess

Min. torque: 2.5 Nm Max. torque: 3 Nm

### ■ 5.4 Cascaded SPDs

Effective protection against overvoltages cannot generally be assured with a single SPD if its protection level (Up) is greater than 1.2 kV (EN/IEC 62305 and TS/IEC 61643-12).



When there are overvoltages, an SPD protects equipment by limiting these overvoltages to values that can be tolerated by the equipment. Thus, depending on its discharge capacity (discharge current In, Imax, etc.) and its protection level (Up), an SPD will limit these overvoltages to varying values depending on the energy levels involved. The overvoltage values likely to be transmitted downstream of the SPD can double over distances of more than 10 m due to resonances associated with the type of electrical installation and the type of equipment.

Overvoltages greater than 2.5 kV can then occur and damage equipment if the residual energy is high enough (2.5 kV being the insulation level of most electrical and electronic equipment, or even 1.5 kV for electrical domestic appliances). SPDs should be installed in the distribution boards supplying equipment that is sensitive or critical for the activity being carried out (and/or near to equipment with proximity SPDs).

## ■ 5.5 Coordinating upstream/downstream SPDs

Consists of ensuring that any downstream SPD (in distribution enclosures or proximity SPDs) is correctly coordinated in energy terms with any SPD located upstream (TS 61643-12).

Minimum distances between SPDs (m)


Unstroom CDD	Downstream SPD	Minimum distance (m)	
Upstream SPD	Stream SPD Downstream SPD		Without LPS*
T1+T2/35 and T1+T2/25	T2/40 (Uc 440V)	0	0
	T2/40 (Uc 320V)	1	0
T1+T2/12.5 and T1+T2/8	T2/40	5	0
	T2/20 or T2/12	8	0
T2/40	T2/20 or T2/12	-	1
T2/20	T2/12	-	0.5
T2/20 and T2/12	Proximity SPDs	-	2

<sup>\*</sup> LPS: Lightning Protection System

### 6. ACCESSORIES


### ■ 6.1 Signalling auxiliary

Cat. Nos 4 122 32/33/42/72/74/75/76/77










### ■ 6.2 Replacement plug-in modules with status indicator

- Green: SPD operational
- Orange: plug-in module needs to be replaced



Module Cat. Nos.	Туре	SPD Cat. Nos.
4 122 97	T2/20 kA	4 122 20/24/25
4 122 98	T2/20 kA (N-PE module)	4 122 24/25
4 122 99	T2/40 kA	4 122 40/42/44/45
4 123 00	T2/40 kA (N-PE module)	4 122 44/45
4 123 01	T2/40 kA (440 V)	4 122 30/32/33
4 123 02	T1+T2/8 kA	4 122 50/51/52/53/54/55/56/57
4 123 03	T1+T2/12.5 kA	4 122 70/71/72/73/74/75/76/77